# SUBMITTAL SHEET

# VOLU-probe / FI-SS FAN INLET AIRFLOW TRAVERSE PROBE VANE AXIAL – FAN INLETS <20" IN DIAMETER

## STANDARD CONSTRUCTION

**Probe**. 3/8" tube. Type 316 stainless steel.

Mounting Brackets. Type 316 stainless steel.

**Connection Fittings**. 1/4" stainless steel compression type union.

### PERFORMANCE SPECIFICATIONS

Accuracy. 3% when installed per recommended installation location at the fan inlet.

Outputs. Individually averaged signals of total and static pressure.

Operating Velocity. 2000 - 12000 FPM.

Operating Temperature. Continuous operation to 200°F. Traverse Pattern. Concentric area circles.

## **DIMENSIONAL SPECIFICATIONS**



