

VELTRON DPT 2500-plus, NEMA 12

MICROPROCESSOR BASED ULTRA-LOW DIFFERENTIAL PRESSURE AND FLOW TRANSMITTER

STANDARD CONSTRUCTION Ultra-low span transmitter with automatic zeroing and a backlit graphical LCD providing single line of data display.
1/8" FPT, brass signal connection fittings.
NEMA 12 enclosure.

- OPTIONS**
- | | | | |
|---|--|--|---|
| <input type="checkbox"/> Uni-Polar (std) Transducer <input type="checkbox"/> Bi-Polar Transducer | Connection Fittings <input type="checkbox"/> 1/4" brass compression type <input type="checkbox"/> 3/8" brass compression type <input type="checkbox"/> Brass barbed for 1/4" OD tubing <input type="checkbox"/> Brass barbed for 3/8" OD tubing | Certification <input type="checkbox"/> Standard <input type="checkbox"/> NIST Traceable | ID Tags <input type="checkbox"/> None (std) <input type="checkbox"/> Plastic <input type="checkbox"/> Stainless |
|---|--|--|---|

PERFORMANCE SPECIFICATIONS

Accuracy. ±0.25% of Natural Span, including non-linearity, hysteresis, deadband, and non-repeatability.

Stability. ±0.5% of Natural Span for six months.

Temperature Effect. Zero. None; corrected by AUTO-zero Span. 0.015% of Full Span/°F.

Mounting Position Effect. None; corrected by AUTO-zero.

Transducer Response Time. 0.5 seconds to reach 98% of a step change.

Power Consumption. 8VA at 24VAC; 6VA at 24VDC.

FUNCTIONAL SPECIFICATIONS

Outputs. Single output. Configurable via jumper for 0-5VDC, 0-10VDC, or 4-20mA DC.

Power Supply. 24VAC (16-30VAC) or 24VDC (16-40VDC).

Low Pass Filtration. Response time to reach 98% of a step change is adjustable from 0.5 to 250.0 seconds.

Overpressure/Static Pressure Limit. 25 psig.

Zero Elevation/Suppression. (Requires Bi-polar Transducer)
Maximum zero elevation: 100% of Natural Full Span.
Maximum zero suppression: 50% of Natural Full Span.

Circuit Protection. Power input is isolated, fused, and reverse polarity protected.

Humidity Limits. 0-95% RH (non-condensing).

Temperature Limits. -20°F to 180°F Storage.
+40°F to 140°F Operating.

Automatic Zeroing.
Accuracy: Within 0.1% of calibrated span.
Frequency: Every 1 to 24 hours on 1 hour intervals.

Span and Zero Adjustment. Digital, via internally located pushbuttons.

